

Mobil Refining Australia Pty Ltd

A.C.N. 004 300 163

Altona Refinery  
Cnr Millers & Kororoit Rds  
Altona, Victoria 3018

Telephone: (03) 92865666  
Facsimile : (03) 92865588

7<sup>th</sup> March 1994

Insultec Australia Pty Ltd

Attn: Mr. Jim Della-Bona

Re: Insultec Paint Trials

As discussed a Refinery Engineer has organized a test of your product on a small surface area leading to a control room air conditioning inlet duct. The surface received the prescribed coating thickness as per your technical advise.

Some of the results to date, indicated a significant surface temperature reduction. During a 32<sup>o</sup>C day the surface temperature of an untreated area was 51<sup>o</sup>C whilst the Insultec treated area had a 33<sup>o</sup>C reading.

Temperature monitoring is continuing with the view of painting the entire ducting to minimize the air conditioning heat load.

The Refinery will be contacting your organisation to recommend a suitable coating for the outside of storage tanks.



J. PAPAGEORGIU  
Snr Project Engineer